

C E R T I F I C A T E
of Conformity

EC Council Directive 2004/108/EC
Electromagnetic Compatibility

Registration No.: AE 50319885 0001

Report No.: 10026145 003

Holder: **HORING LIH INDUSTRIAL CO., LTD.**
4F., NO. 18,
LANE 327, SEC. 2, CHUNG SHAN RD.,
ZHONGHE DIST., NEW TAIPEI CITY 235
Taiwan

Product: Fire Alarm Device
(Fire Alarm System)

Identification: see Appendix

Tested acc. to: EN 61000-6-3:2007+A1
EN 50130-4:2011

This certificate of conformity is based on an evaluation of a sample of the above mentioned product. Technical Report and documentation are at the Licence Holder's disposal. This is to certify that the tested sample is in conformity with all provisions of Annex I of Council Directive 2004/108/EC. This certificate does not imply assessment of the production of the product and does not permit the use of a TÜV Rheinland mark of conformity. The holder of the certificate is authorized to use this certificate in connection with the EC declaration of conformity according to the a.m. Directive.



Certification Body



Dipl.-Ing. F. Stoelzel

Date 02.09.2015

TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg

CE The CE marking may only be used if all relevant and effective EC Directives are complied with. CE

Appendix to TÜV Certificate of Conformity No.: AE 50319885 0001

Certified Product : Fire Alarm System
Report Number : 10026145 003
Type Designation : See below for details

Product Name	Product type	Model Number
Fire Alarm System	Addressable Control Panel	AH-05316, QA16, BMT-16
Fire Alarm System	Control Module	AH-06717B, QA17-B, AH-00217B, BMT-17B
Fire Alarm System	Output Module	AH-00217A, QA17-A, BMT-17A
Fire Alarm System	Monitor Module	AH-00217K, QA17-K, BMT-17K
Fire Alarm System	Isolator Module	AH-00217H, QA17-H, BMT-17H
Fire Alarm System	Addressable Manual Call Point	AH-00119, QA19, QA19-A
Fire Alarm System	Addressable Smoke Detector	QA01, BMT-01
Fire Alarm System	Addressable ROR Detector	QA03
Fire Alarm System	Addressable FT Detector	QA37
Fire Alarm System	Addressable Smoke & Heat Detector	QA05
Fire Alarm System	Addressable Heat Detector	QA06, BMT-06
Fire Alarm System	Manual Call Point	AH-9717, YH-9717, FL-9717
Fire Alarm System	Indicating Lamp	AH-9719, YH-9719
Fire Alarm System	Remote Indicator	AH-01313
Fire Alarm System	Remote Indicator	AH-91213
Fire Alarm System	Addressable Base	AH-00118

Date: September. 02, 2015



Certification Body

Dipl.-Ing. F. Stoelzel